

MOST COMMONLY RED-TAGGED ITEMS

FOUNDATION	<ol style="list-style-type: none">1. Cable ends not taped2. Exposed copper3. Rebar placement4. No plans on job5. Water and debris in beams6. No brick ledge7. Too wet8. No address9. No form survey
FRAMING	<ol style="list-style-type: none">1. Joist blocking2. Improper plate shots3. Wind bracing4. Chimney chase fire blocking5. Purlin struts to joists6. Work not ready7. Trades not finished8. Not dried in9. Sheathing not sealed10. Seal fire wall11. No plans
MECHANICAL, ELECTRICAL, PLUMBING	<ol style="list-style-type: none">1. Work not finished2. Water heater vent against combustibles3. Nail guards4. G.F.I. plug locations5. Switches too close to tubs and showers6. Smoke detector locations7. Installation not complete8. Bonding9. Seal holes in plenums
FINALS & C.O.	<ol style="list-style-type: none">1. Work not complete2. Water meter covered3. G.F.I.s not working4. Address numbers on back of house5. Access and working space on attic equipment6. Gas not hooked up to appliances7. Grading surveys not submitted on front entry8. Energy form
FENCE	<ol style="list-style-type: none">1. Fence clips2. Height
SIGN	<ol style="list-style-type: none">1. Needs electrical place to enter